

2010 Consumer Confidence Report for 61702641

ELK MOUND WATERWORKS

Water System Information

If you would like to know more about the information contained in this report, please contact Terry Stamm at (715) 879-5805. The Village Board meets the first and third Tuesday of each month at the Village Hall at 7:00 p.m.

Health Information

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's safe drinking water hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune systems disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbial contaminants are available from the Environmental Protection Agency's safe drinking water hotline (800-426-4791).

Source(s) of Water

Source id	Source	Depth (in feet)	Status
1	Groundwater	280	Active
2	Groundwater	352	Active

The assessment can be accessed by the DNR website: The source water assessment is intended to provide basic information regarding where your drinking water comes from and the degree to which it may be impacted by potential sources of contamination. To locate a full assessment for your Public Water Supply System:

1. Go to the Wisconsin Department of Natural Resources website on the internet at <http://dnr.wi.gov>.
2. On the left side of the page, left click your mouse on Environmental Protection.
3. Under Environmental Protection, scroll down and left click mouse on Water. This will bring up Division of Water.
4. Under Water Programs, left click mouse on Drinking Water and Groundwater.
5. Under Our Programs, left click mouse on Source Water Assessment Program.
6. In the main page left click mouse on Find an Assessment. This will take you to DNR's Water Quality Database.

7. Type in ELK MOUND WATERWORKS and press enter.
8. In the box that appears, you will see the facility name, DNR PWS ID#, and whether or not a source Water Assessment is available.
9. To obtain a copy of the summary for your facility, left click on the phrase "Summary Available".

Educational Information

The sources of drinking water, both tap water and bottled water, include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally- occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which shall provide the same protection for public health.

Number of Contaminants Required to be Tested

This table displays the number of contaminants that were required to be tested in the last five years. The CCR may contain up to five years worth of water quality results. If a water system tests annually, or more frequently, the results from the most recent year are shown on the CCR. If testing is done less frequently, the results shown on the CCR are from the past five years.

Contaminant Group	# of Contaminants
Disinfection Byproducts	2
Inorganic Contaminants	16
Microbiological Contaminants	2
Radioactive Contaminants	3
Unregulated Contaminants	4
Volatile Organic Contaminants	20

Disinfection Byproducts

Contaminant (units)	MCL	MCLG	Level Found	Range	Sample Date (if prior to 2010)	Violation	Typical Source of Contaminant
TTHM (ppb)	80	0	1.9	1.9		NO	By-product of drinking water chlorination

Inorganic Contaminants

Contaminant (units)	MCL	MCLG	Level Found	Range	Sample Date (if prior to 2010)	Violation	Typical Source of Contaminant
BARIUM (ppm)	2	2	.002	.002	04/08/2008	NO	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
COPPER (ppm)	AL=1.3	1.3	.5970	0 of 10 results were above the action level.	04/16/2008	NO	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
LEAD (ppb)	AL=15	0	3.00	0 of 10 results were above the action level.	04/18/2008	NO	Corrosion of household plumbing systems; Erosion of natural deposits
SODIUM (ppm)	n/a	n/a	1.73	1.73	04/08/2008	NO	n/a

Radioactive Contaminants

Contaminant (units)	MCL	MCLG	Level Found	Range	Sample Date (if prior to 2010)	Violation	Typical Source of Contaminant
GROSS ALPHA, EXCL. R & U (pCi/l)	15	0	1.4	1.4	09/28/2009	NO	Erosion of natural deposits

GROSS ALPHA, INCL. R & U (n/a)	n/a	n/a	1.4	1.4	09/28/2009	NO	Erosion of natural deposits
RADIUM, (226 + 228) (pCi/l)	5	0	1.4	1.4	09/28/2009	NO	Erosion of natural deposits

Unregulated Contaminants

Contaminant (units)	MCL	MCLG	Level Found	Range	Sample Date (if prior to 2010)	Violation	Typical Source of Contaminant
BROMODICHLOROMETHANE (ppb)	n/a	n/a	.63	.63		NO	n/a
BROMOFORM (ppb)	n/a	n/a	.26	.26		NO	n/a
CHLOROFORM (ppb)	n/a	n/a	.33	.33		NO	n/a
DIBROMOCHLOROMETHANE (ppb)	n/a	n/a	.67	.67		NO	n/a

Definition of Terms

Term	Definition
MCL	Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
MCLG	Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
pCi/l	picocuries per liter (a measure of radioactivity)
ppm	parts per million, or milligrams per liter (mg/l)
ppb	parts per billion, or micrograms per liter (ug/l)